

## **12.10.220 Cross connections.**

The installation or maintenance of any uncontrolled cross connection that may endanger the quality of the public water supply of the City is prohibited. Any such cross connection now existing or hereafter installed is hereby declared unlawful and shall be abated immediately. The control and/or elimination of cross connections shall be in accordance with the applicable sections of the Washington Administrative Code (“WAC”) the Tacoma Municipal Code, and the Policies and/or procedures approved by the Division. Failure to comply with Division cross connection control requirements may result in a penalty of \$100 per occurrence, installation of an approved backflow prevention assembly at the water meter at the expense of the customer, and/or termination of water service. For purposes of this section, an occurrence is defined as failure to install, test, repair, and/or replace a required backflow prevention assembly upon written notification by the Division delivered by hand or registered mail. Responsibility for backflow assembly testing and payment of all penalties and/or fees are the responsibility of the customer receiving the water service. The Division will assign a test due date for each backflow prevention assembly and will make every effort to provide notice to the customer of the testing due date. Annual backflow assembly testing will be required by the Division established due date regardless of the actual date previous tests were performed.

(Ord. 27778 Ex. A; passed Jan. 6, 2009; Ord. 27522 § 11; passed Aug. 29, 2006; Ord. 26800 § 11; passed Apr. 10, 2001; Ord. 26048 § 1; passed Mar. 25, 1997)